

DITEK Corporation ONE DITEK CENTER 1720 Starkey Road Largo, FL 33771



## INSTALL INSTRUCTIONS D200-347/6003Y

**NOTICE:** This SPD should be installed by a licensed contractor in accordance with all applicable National and Local Electrical Codes and the following instructions.

## APPLICATION

Type 1 SPD for hardwired installation on a 347/600 VAC 3 phase Wye electrical service.

## INSTRUCTIONS:


Caution: Measure all voltages to verify applied voltage does not exceed the voltage rating of the unit. Reference the Expected System Voltages chart below. Improper installation voids the warranty.

**NOTE**: Suitable for use on a circuit capable of delivering not more than 100,000 rms symmetrical Amperes. Recommended circuit breaker size is 30 Amps. This SPD contains no serviceable parts.

- 1. Turn off the power at the main breaker or service disconnect before beginning installation.
- 2. Remove front cover from the electrical panel.
- 3. Determine the ideal mounting position of the SPD by orienting the unit as close as possible to the position of the circuit breaker selected for the SPD connection.
- 4. Remove a 3/4" knockout in the electrical panel or drill a 3/4" NPT hole in the electrical panel.
- 5. See the Illustrations Page on the back side of this document for instructions on assembling the included liquid-tight conduit and connector. The conduit length can be cut down shorter if desired.
- 6. Remove "Locknut A" from the conduit connector.
- 7. Feed all wires, conduit and 3/4" NPT connector through the knockout hole in the panel, and finally tighten "Locknut A" on the conduit connector.
- 8. Connect the Ground wire (Green) to the Ground bus inside of the panel.
- 9. Connect the Neutral wire (White) to the Neutral bus inside of the panel.
- 10. Connect the (3) Phase wires (Black) to the load side of the 3-pole circuit breaker.
- 11. Securely mount the enclosure with appropriate anchors by using the mounting feet located at each corner.
- 12. After all connections have been made and no hazards exist, replace panel cover and restore power.

Audible Alarm Operation: This SPD includes an audible alarm that will sound when the unit has self-sacrificed and is no longer providing protection. To silence the audible alarm, power to the SPD needs to be turned off via the circuit breaker or service disconnect.

**Dry Contact Connection:** This is a Form C Dry Contact Circuit, 0.9A, 240VAC maximum input. Normally Open (NO)=Black Wire, Common (COM)= Red Wire, Normally Closed (NC)=White Wire. **Note:** Remote Alarm Wires To Be Connected To Class 1 Circuits Only.



DRAWN BY: BRIAN AYCOCK 12/13/23 APPROVED BY: MIKE MOLINARI 12/13/23 DITEK TECHNICAL SUPPORT 1-888-472-6100 www.diteksurgeprotection.com

DOC # INT-100140-001 PART NO. 191562 REV. 5

