

INSTALLATION BEST PRACTICES



Conductor Length $\geq$ 3 ft

The conductor length between the SPD and the equipment being protected should be a minimum of three feet in length to allow enough time for the SPD to react. The conductors can be greater than three feet as long as they are isolated and are not subjected or directly exposed to internally- or externally-generated transient voltage spikes and/or surges.



Utilize separate conduit feeds

Always make sure that the field wiring (unprotected wires) and the protected wiring occupy separate conduit feeds. When unprotected and protected wires occupy the same conduit, surge energy can be induced on to the protected wiring and completely bypass the surge protective device.

Use grounding bus bars

The use of a grounding bus bar is strongly recommended as a means of terminating SPD ground wires to existing electrical grounding leads. This will ensure a solid mechanical connection of all grounding wires.

The use of twist-on wire connectors ("wire nuts") is not recommended for termination of SPD ground wires to existing electrical grounding leads. Twist-on wire connectors can increase ground resistance, may become loose and/or corroded over time, and can also unnecessarily extend the length of the grounding conductor. This would degrade the performance of the SPD due to the lack of a short, low impedance ground path.

Use dedicated enclosures

Whenever possible, Surge Protective Devices should be installed in a dedicated enclosure outside of the equipment being protected. This will prevent physical damage to the electronic circuit board, power supply and/or wiring inside of the equipment panel due to a potential catastrophic failure of the SPD.

Use a dedicated ground wire

When installing multiple SPDs and terminating to a common electrical ground, a dedicated ground wire running from each individual SPD to a common grounding bus bar is strongly recommended. "Daisy-chaining" multiple SPD ground wires together via the SPD grounding terminals, or by using twist-on wire connectors, is not recommended as this increases the resistance and extends the length of the ground path.

CONTACT US

SALES 800-753-2345

TECH SUPPORT 888-472-6100

Try our online product selector tool to help find the right surge protection devices.

www.DITEKsurgeprotection.com